



STATE OF WASHINGTON

DEPARTMENT OF HEALTH
OFFICE OF DRINKING WATER

243 Israel Road SE • Town Center #3 • PO Box 47822 • Olympia, Washington 98504-7822
TDD Relay Service: 1-800-833-6388

NOTICE*

Wilkins 950XL TU Double Check Valve Assembly Now Approved

As of August 14, 2006, the Wilkins 950XL TU double check valve assembly (¾" and 1" sizes, horizontal installation only) is approved by the Department of Health to protect drinking water from contamination in Washington.

State drinking water rules require backflow assemblies installed to protect public water systems to be on the current list of assemblies approved for use in Washington [(WAC 246-290-490(5)(a)]. Purveyors and others should always verify the approval status of an assembly (make, model, size and orientation) before they install or accept an assembly for protection of the public water system. Purveyors can verify an assembly's approval status by checking the *DOH-Approved Assemblies List*.

DOH will be adding the Wilkins 950XL TU to the next published *DOH-Approved Assemblies List* (DOH publication #331-137). You may request a copy of the *DOH-Approved Assemblies List* at:

<http://www4.doh.wa.gov/dw/publications/publications.cfm?action=pubdetail&PubId=333>

For more information, call Terri Notestine at (360) 236-3133 or e-mail terri.notestine@doh.wa.gov

**Note: This Notice supersedes the April 2006 Notice to purveyors that the Wilkins 950XL TU assembly was not DOH-approved to protect drinking water from contamination in Washington.*

September 6, 2006